

# PUBLIC POOL BATHING PLACE

Userid: BuchananVR

STATE OF FLORIDA  
DEPARTMENT OF HEALTH *MG*  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT

Geocoded 28.591324/-80.803582

**PURPOSE:**

- ROUTINE     REINSPECTION  
 CONSTRUCT.     CHANGE OF OWNER  
 COMPLAINT     CONSULTATION  
 QA SURVEY     EPIDEMIOLOGY  
 OTHER

TYPE: Public Pool > 25000 Gallons



NAME Titusville High School SWP  
 ADDRESS 150 Terrier Trail S CITY Titusville  
 OWNER Brevard County School Board ZIP 32780  
 PERSON IN CHARGE Brevard County School Board PHONE (321) 720-2482  
 POOL OPERATOR Maintenance PHONE (321) 720-2482  
 E-MAIL rhinelander.martin@brevardschools.org

- RESULTS:**  
 Satisfactory  
 Incomplete  
 Pool Closed  
 Unsatisfactory  
 OUT OF BUSINESS

Correct Violations by  
 Next Inspection  
 8:00 AM on:

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
12:30	13:45	11/20/2012	62175	05-60-11049

Re-inspection Date
11/23/2012

*Items marked below are not in compliance the requirements of Chapters 64E-9 of the Florida Administrative Code and must be corrected. Continued operation of this facility without making these corrections is a violation of Chapter 64E-9 of the Florida Administrative Code and Chapters 386 and 514, Florida Statutes. Violations must be corrected as indicated in the Results section above or an administrative fine or other legal action will be initiated.*

POOL AREA	POOL SAFETY	EQUIPMENT ROOM	POOL SPECIFICATIONS								
<input type="checkbox"/> 1. Appearance/Water Control	<input type="checkbox"/> 14. Life Hook w/Pole <i>OK</i>	<input type="checkbox"/> 25. Spa Requirements	<table border="1"> <tr><th>VOLUME</th></tr> <tr><td>212000</td></tr> <tr><th>POOL LOAD</th></tr> <tr><td>125</td></tr> <tr><th>FLOW RATE</th></tr> <tr><td>600</td></tr> <tr><th>FILTER TYPE</th></tr> <tr><td>DEV</td></tr> </table>	VOLUME	212000	POOL LOAD	125	FLOW RATE	600	FILTER TYPE	DEV
VOLUME											
212000											
POOL LOAD											
125											
FLOW RATE											
600											
FILTER TYPE											
DEV											
<input type="checkbox"/> 2. Deck/Walkways <i>OK</i>	<input type="checkbox"/> 15. Life Ring w/Rope <i>OK</i>	<input type="checkbox"/> 26. Warning Pool-Quick Dump									
<input checked="" type="checkbox"/> 3. Tile/Pool Finish <i>Worn</i>	<input type="checkbox"/> 16. Safety Line/2" Markings <i>gone</i>	<input type="checkbox"/> 27. Water Level/Control									
<input type="checkbox"/> 4. Depth Markings	<input type="checkbox"/> 17. Rules Posted <i>OK</i>	<input type="checkbox"/> 28. Disinfection Feeder <i>OK</i>									
<input checked="" type="checkbox"/> 5. Handrail/Ladder <i>10 tread</i>	<input type="checkbox"/> 18. Certification	<input type="checkbox"/> 29. pH Feeder									
<input type="checkbox"/> 6. Step Markings <i>gone</i>	<b>SANITARY FACILITIES</b>	<input type="checkbox"/> 30. Chem. Container Labels <i>OK</i>									
<input type="checkbox"/> 7. Main Drain Grate <i>W/12</i>	<input type="checkbox"/> 19. Supplies	<input checked="" type="checkbox"/> 31. Filter Pump <i>1.5 HP</i>									
<input type="checkbox"/> 8. Gutter/Grales/Swimmer	<input type="checkbox"/> 20. Clean <i>OK</i>	<input checked="" type="checkbox"/> 32. Vacuum Cleaner <i>2 HP</i>									
<input type="checkbox"/> 9. Lighting <i>none</i>	<b>WATER QUALITY</b>	<input type="checkbox"/> 33. Flowmeter <i>500</i>									
<input type="checkbox"/> 10. No Dive Markings <i>syn AS</i>	<input type="checkbox"/> 21. Approved Test Kit	<input type="checkbox"/> 34. Thermometer <i>72</i>									
<input checked="" type="checkbox"/> 11. Diving Board <i>rusty</i>	<input type="checkbox"/> 22. Free Chlorine/Bromine <i>3.0</i>	<input type="checkbox"/> 35. Reverse/Vacuum Gauge									
<input type="checkbox"/> 12. Pool Cover <i>OK</i>	<input type="checkbox"/> 23. pH <i>7.4</i>	<input type="checkbox"/> 36. Equip. Room <i>OK</i>									
<input checked="" type="checkbox"/> 13. Pool Side Shower <i>OK</i>	<input type="checkbox"/> 24. Chlor. Stabilizer	<input type="checkbox"/> 37. Cross Connection									
		<input type="checkbox"/> 38. <del>Chlorine Equip.</del>									
		<input type="checkbox"/> 39. Waste Water Disposal <i>OK</i>									
		<input type="checkbox"/> 40. D.E. Separator <i>OK</i>									
		<input checked="" type="checkbox"/> 41. Other Equipment <i>OK</i>									
		<input type="checkbox"/> 42. Equipment Change									
		<input type="checkbox"/> 43. Approved Chemicals									
		<input type="checkbox"/> 44. Maintenance Log <i>OK</i>									
		<input type="checkbox"/> 45. Inspection Posted <i>OK</i>									
		<input type="checkbox"/> 46. Electrical Equip. <i>OK</i>									
		<input type="checkbox"/> 47. Fences <i>OK</i>									
		<input type="checkbox"/> 48. Other									
		<input type="checkbox"/> 49. Other									

**COMMENTS AND INSTRUCTIONS**

Violation #3 Patch all worn or chipped areas on pool surface. Pool surface is badly worn and there is a leak along the east gutter allowing water onto the deck. This area must be maintained free of mold and slip resistant. Pool must be resurfaced no later than Dec. 31, 2012. If resurfacing and repairs are not accomplished by the next routine inspection, administrative action could result.  
 Code Reference FAC: Tile/Pool Finish: 64E-9.004(3). Pool finish and tile shall be in good repair.

Violation #5 Replace missing non-slip treads.  
 Code Reference FAC: Handrail/Ladder: 64E-9.006(1)(d)5. Handrails must be provided for all pool steps and must be securely anchored in the pool deck and the bottom step. "Figure Four" handrails must be securely anchored in the pool deck and must extend to the bottom step. Ladders must be provided and must be securely anchored in the pool deck and must rest against the pool wall with a 3 to 6 inch clearance.

Violation #11 Replace rusted mounting hardware on diving boards.  
 Code Reference FAC: Diving Board: 64E-9.006(1)(g)3. Diving boards must be secured and slip resistant. If diving boards are removed the stanchions must be removed.

Violation #31 Maintain flowrate between +/- 10% of designed flowrate of 600gpm. Adjust flow rate to between 540 and 660 gpm.  
 Code Reference FAC: Filter Pump: 64E-9.007(2) & (4). The filter pump shall be properly sized and

\*\*Continued On Page 2\*\*

INSPECTION CONDUCTED BY: Vern Buchanan PHONE: (321) 633-2100 ex. 56235  
 INSPECTION COND SIGNATURE: [Signature] (321) 537-2988  
 COPY OF REPORT RECEIVED BY: [Signature] DATE: 11/20/2012

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY PUBLIC HEALTH UNIT  
Swimming Pools/Spa



Name: Titusville High School SWP

Date: 11/20/2012

Identification No: 05-60-11049

**Comments and Instructions (Continued from Page 1):**

operable.

Violation #32 Vacuum port cover is missing - replace.

Code Reference FAC: Vacuum Cleaner, 64E-9.007(12). All pools shall have a vacuum cleaning system. (Except for spa and wading pools of less than 200 square feet.)

*Completed*

Violation #41 Replace all missing wall returns.

Code Reference FAC: Other Equipment, 64E-9.005(7). Auxiliary equipment must not interfere with the attainment of the design flow, i.e. ionizers, ozone generators, etc.

Violation 32 (missing vacuum port cover) must be corrected by Nov. 23, 2012 to avoid a \$50 fee for subsequent re-inspections. You may fax corrections to your violations to 321-633-2151 or email to vern\_buchanan@doh.state.fl.us.

*By  
Next  
Inspection*

All other violations must be corrected by next routine inspection.

Copy of Report  
Received By: *Mary Miller*

Inspector Vern Buchanan

## **Rhinelander, Martin@Facilities**

---

**From:** Vern\_Buchanan@doh.state.fl.us  
**Sent:** Tuesday, November 20, 2012 4:03 PM  
**To:** Rhinelander, Martin@Facilities  
**Subject:** Health Department Inspection Results - Keep this document for your records.  
**Attachments:** Titusville High School SWP\_11\_20\_2012\_RO\_05\_60\_11049.PDF

Good afternoon, attached is your copy of today's pool inspection report for the Titusville High School SWP.

To answer your question regarding Violation 3 (pool finish), administrative actions are used when other attempts to achieve compliance have failed. Initially a "Notice of Non-Compliance" is issued restating the violation, describing the actions needed to correct and establishing a reasonable time-frame to make the corrections. Once that suspense date has passed a "Letter of Intent" to impose an administrative fine and to schedule a pre-lawsuit conference is issued. Once the "Administrative Complaint" is filed the matter is turned over to legal. Please let me know if you have any questions.  
Thanks

Keep this document for your records

**Verner R. Buchanan, R.S.**  
Environmental Specialist II  
Brevard County Health Department  
2725 Judge Fran Jamieson Way, Suite A116  
Viera, FL 32940  
(321) 633-2100 Ext. 56235 office  
Fax: 321 633-2151 Fax

Please Note: Florida has a very broad public records law. Most written communications to or from state officials regarding state business are public records available to the public and media upon request. Your email communication may therefore be subject to public disclosure.

Vacuum Port is Plugged off AS OF 11-21-12.